## PROJECT SUMMARY

NAME OF SOURCE OWNER:

UGI Development Company

SOURCE IDENTIFICATION:

Hunlock Station Unit 6

LOCATION OF SOURCE:

Route 11, PO Box 224 Hunlock Creek, PA 18621

TYPE OF OPERATION:

Coal Fired Utility Steam Generator

TYPES OF TESTS PERFORMED:

Sample Traverse-EPA Method 1 Volumetric Flow Rate-EPA Method 2F Oxygen/Carbon Dioxide-EPA Method 3A

Particulate-ASTM D6831-02

SOURCE ANALYZERS:

Air Monitor Mastron Electronic Flow - B26354 Thermo Environmental SO<sub>2</sub> - 43C-69110-362 Thermo Environmental NOx - 42C-69062-362 Thermo Environmental CO<sub>2</sub> - CHL-68209-359

United Sciences Model 500C Opacity VIM Technologies DAHS - 14787WIN

TEST COMPANY:

Catalyst Air Management, Inc.

10 Mill Road

Morgantown, PA 19543

PA Lab Registration Number 6-3118

Mike Taylor - President

(865) 531-0075

SITE SUPERVISOR:

Jeff Ferguson - Principal

TEST PERSONNEL:

Dustin Urban - Technician

Jack McKeever - Clean Air Engineering

TEST DATE:

May 1, 2008

OWNERS REPRESENTATIVE:

Jeff Steeber

TEST OBSERVER:

Darren Lauer - PADEP

## 1.0 Introduction

Catalyst Air Management, Inc. (Catalyst) was contracted by UGI Development Company (UGI) to perform particulate emissions testing at Hunlock Station Unit 6 in Hunlock Creek, PA. The particulate emissions of the unit is affected under 40 CFR Part 64, the Compliance Assurance Monitoring Rule (CAM). The testing was performed using a Tapered Element Oscillating Microbalance (TEOM) 7000. The testing was performed to collect and assess real-time particulate mass concentration and emissions data to develop a CAM plan based on the plant opacity data.

The sampling program was conducted May 1, 2008. The RATA was performed by Messrs. Jeff Ferguson and Dustin Urban of Catalyst and Mr. Jack McKeever of Clean Air Engineering. Mr. Jeff Steeber of UGI coordinated plant operation during the testing.

## 2.0 Summary of Test Results

A summary of test results developed by this source sampling program are presented in Tables 1 through 9. The summary tables are presented as follows:

m. 1.1.	Description	Page
Table	Summary of TEOM 7000 Results	1
1	Opacity / PM Concentration Summary	2
2	Opacity / PM Emission Rate Summary	3
3		5
4	Operating Summary	2770

## 3.0 Results of Testing

The results from the TEOM testing are tabulated in Appendices 1 through 5.

TABLE 1 Summary of TEOM 7000 Results

LOAD (MW)	CONDITION	Average Mass Concentration (mg/m³)	Average Emission Rate (lb/mmBtu)
45	Steady State	17.1	0.017
45	ESP Detune	203.3	0.233
35	Steady State	17.2	0.017
25	Steady State	14.4	0.015

PM Concentration (mg/cm) Opacity / PM Concentration Opacity/PM Concentration Summary Opacity (%) Series1

TABLE 2

PM Emission Rate (lb/mmBtu) 0 20 Opacity / PM Emission Rate 40 Opacity (%) 50 60 70 80 ♦ Series 1

TABLE 3
Opacity/Emission Rate Summary